

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-1496:124 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** Firecom Inc., 39-27 59<sup>th</sup> Street, Woodside, NY 11377  
Contact: Howard Kogen (718) 899-6100

**DESIGN:** Model F600-250 ionization type smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as ionization smoke detector for use with listee's Model F600-MB-6, F600-MB-6LP, F600-MB-6RLY, F600-MB-6RLED or F600-MB-6GLED (CSFM Listing No. 7300-1496:128) mounting base and separately listed compatible fire alarm control units.

**XLF:** 7271-1394:101

02-19-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**APRIL 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager